



The following information is being provided to insure that all parties are aware and understand the requirements for cooking operations during special events. The information provided below is the minimum requirements as included in the Florida Fire Prevention Code FFPC (2007 Edition). These requirements will be subject to on-site inspection and review. Any deviations to minimum requirements shall only be allowed with the approval of the authority having jurisdiction.

### **10.11.2 Open Fires**

- **10.11.3** Open fires and cooking fires shall be constantly attended by a competent person until such fire is extinguished. This person shall have a garden hose connected to the water supply or other fire-extinguishing equipment readily available.

**10.11.4** The AHJ shall have the authority to prohibit any or all open fires when atmospheric conditions or local circumstances make such fire hazardous.

- **10.15 Special Outdoor Events, Carnivals, and Fairs**

**10.15.2** The AHJ shall be permitted to regulate all outdoor events such as carnivals and fairs as it pertains to access for emergency vehicles; access to fire protection equipment; placement of stands, concession booths, and exhibits; and the control of hazardous conditions dangerous to life and property.

- **10.15.8 Cooking.** Concession stands utilized for cooking shall have a minimum of 10 ft (3 m) of clearance on two sides and shall not be located within 10 ft (3 m) of amusement rides or devices.

**50.1.1\*** The design, installation, operation, inspection, and maintenance of all public and private commercial cooking equipment shall comply with this chapter and [NFPA 96](#), *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*.

**50.2.1.1** Cooking equipment used in processes producing smoke or grease laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this chapter. [96:4.1.1.2]

**50.2.1.1.1** Cooking equipment that has been listed in accordance with UL 197, Standard for Commercial Electric Cooking Appliances, or an equivalent standard for reduced emissions shall not be required to be provided with an exhaust system [96:4.1.1.1]

**50.2.1.9\*** Cooking equipment used in fixed, mobile, or temporary concessions, such as trucks, buses, trailers, pavilions, tents, or any form of roofed enclosure, shall comply with NFPA 96 or this chapter. [96:4.1.9]

***Page 2 is required to be signed.***



**NFPA 96 (2004 Edition)**

**10.1.1** Fire-extinguishing equipment for the protection of grease removal devices, hood exhaust plenums, and exhaust duct systems shall be provided.

**10.1.2\*** Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment.

**10.2.1** Fire-extinguishing equipment shall include both automatic fire-extinguishing systems as primary protection and portable fire extinguishers as secondary backup.

**I attest that all requirements noted above have been met or addressed in the documentation provided for review and approval and understand that inadequate or incorrect content is cause for permit denial.**

\_\_\_\_\_  
Signature of Applicant or Applicant's Representative

\_\_\_\_\_  
Date